



Water Storage Suggestion – Requirement

Water is limited in quantity and in some areas of the Perrydale Domestic Water Association (PDWA) service area the pressures are limited too. For these reasons we suggest that homeowners have a storage tank that holds 100 to 1000 gallons. When pressures are limited a booster pump from the tank to the house will be needed to provide adequate pressure for household use.

(Check the boxes that apply)

- PDWA recommends that the member have a storage tank on their side of the meter.
- PDWA recommends that the member have a booster pump.
- PDWA recommends _____
- _____
- PDWA requires that the member have a storage tank on their side of the meter.
- PDWA requires that the member have a booster pump.
- PDWA requires _____
- _____

Storage tank and booster pump requirements include:

- Apply for the proper building permits.
- Plans for the tank and/or are to be submitted to PDWA for review.
- The end of the inlet line must be a minimum of 6 inches above the maximum water level in the tank.
- The tank shall be equipped with an overflow outlet which will not allow the water surface within 6 inches of the inlet pipe.
- The float valve mechanism and inlet pipe must be accessible for inspection and maintenance.
- Booster pumps shall be sized for the elevation lift needed and water volume available at the service.
- Prior to use the tank and/or booster pump installation shall be inspected for approval or disapproval by PDWA.

Service Address _____

Member Signature _____ Print Name _____

Date _____

Perrydale Domestic Water Association _____