



WATER STORAGE REQUIREMENT

Water is limited in quantity in the Perrydale Domestic Water Association (PDWA) service area. To maintain adequate pressure throughout the PDWA system the board of Directors has established the following requirements. All new water services are required to have a 4 GPM flow restrictor and a minimum of a 1000-gallon storage tank close to the meter.

The water storage tank needs to be close enough to the meter so that the 4 GPM flow will fill the tank without any assistance. If a tank is placed too far from the meter or higher than the meter, 4 GPM flow may not be adequate to fill the tank.

Members may choose to have a tank larger than 1000 gallons. The American Red Cross recommends three days of water be stored. There are tools you can use to figure out your daily water use. It is recommended that the water storage tank be buried.

Booster pumps: Booster Pumps are only to pump from the member's water storage tank. No booster pump is to be attached directly to the PDWA water system.

Should the member not install a water storage tank PDWA has the right to turn off and lock the meter in the off position until the member installs a water storage tank. Written notice will be sent to the member indicating when the meter will be turned off if a water storage tank is not installed.

Service Address: _____

Member Signature: _____

Print Name: _____

Date: _____

Perrydale Domestic Water Association Signature: _____